




Equipment Imaging and Solutions, Inc.

Thermography Report



IR information	Value
Date of creation	4/16/2002
IR Text Comment	Value
Station	Texas Sub
Equipment Number	311
Weather	Sunny
Description	Left phase hinge heating
Object parameter	Value
Ambient temperature	26.0°C
Label	Value
AR01 : max	>120.0°C

**Comments: Temp on hinge above 450c
Crew planning on bypassing with fuse.
Adjacent phase temp - 45c.**